

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Harrison Park K-8 School - Test 6**

Sample Identification #	Location	Date Time Collected	Date Analyzed	Lab ID	Parameter	Results	Detection Limit	PPS Action Level	Units
236-DF-5837-N/A-006-A	Kitchen	9/29/2021	10/5/2021	A1J0003-02	Lead	0.338	0.2	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek